

▪ 1.0 Clash summary

LG1

	Arch. Walls	Arch. Floors	Door	Window	Structure wall	Structure floors	Column	Beam	Staircase	Air duct	Pipe	Cable tray	Trunking	Equipment
(A) ARC/STR/MEP issues														
Arch. Walls	0	0	0	0	1	0	0	0	0	51	244	20	40	0
Arch. Floors	-	1	0	0	0	0	0	0	0	0	19	0	0	0
Door	-	-	0	0	0	0	0	1	0	7	11	1	0	0
Window	-	-	-	0	0	6	6	0	0	1	2	0	3	0
Structure walls	-	-	-	-	0	0	0	1	0	8	28	4	0	0
Structure floors	-	-	-	-	-	0	0	4	1	8	29	10	0	0
Column	-	-	-	-	-	-	0	0	0	1	0	0	0	0
Beam	-	-	-	-	-	-	-	0	0	1	4	2	2	0
Staircase	-	-	-	-	-	-	-	-	2	0	20	0	0	0
Air duct	-	-	-	-	-	-	-	-	-	63	53	4	0	0
Pipe	-	-	-	-	-	-	-	-	-	-	121	4	21	0
Cable tray	-	-	-	-	-	-	-	-	-	-	-	0	1	0
Trunking	-	-	-	-	-	-	-	-	-	-	-	-	11	0
Equipment	-	-	-	-	-	-	-	-	-	-	-	-	-	0
Arch. Self-clash														1
Stru. Self-clash														5
MEP Self-clash														278
Arch & Stru. clash														14
Arch. & MEP clash (Door)														19
Stru. (Walls) & MEP clash														40
Stru. (Slabs) & MEP clash														47
Stru. (Beams) & MEP clash														9
Stru. (Columns) & MEP clash														1
(A)Sum up														414